CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





LISTING No. 8750-2228:0500 Page 1 of 1

CATEGORY: 8750 -- DRY CHEMICAL OR DRY POWDER PORTABLE FIRE EXTINGUISHER

LISTEE: La Sierra Fire Equipment, Inc.729 West La Cadena Drive, Riverside, CA 92501

Contact: Randy Rousseau (951) 359-7198 Fax (951) 789-2619

Email: lsfe@earthlink.net

DESIGN: Eliminator ™ Model 0930001, dry chemical, portable, cartridge operated fire extinguisher, 6

Ib nominal agent capacity, -40°F to 120°F operating, range.

RATING: 3-A:40-B:C

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as a dry chemical, portable fire extinguisher in accordance with UL 299, UL 711.



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: July 01, 2020 Listing Expires June 30, 2021

Authorized By: **DAVID CASTILLO,**, M.E., F.P.E.

Fire Engineering Division